date last updated: 10/28/2020

School Name: Lake George Junior-Senior High School

Lab ELAP id#: 10709 | **Method of analysis: ICP/MS - EPA 200.8 REV 5.4**

Lab ID#	School sample id	collection date	Sample location	Outlet description	Initial/post remediation	Lead result ug/L (ppb)	lab report receipt date	Action Taken
201002051-001	2	10/2/2020	HS 2nd Fl South	Bottle Fill	Initial	Not Detected (<1)	10/14/2020	n/a
201002051-002	3	10/2/2020	HS 2nd Fl Faculty Room	Sink	Initial	Not Detected (<1)	10/14/2020	n/a
201002051-003	4	10/2/2020	HS 1st Fl North	Bottle Fill	Initial	Not Detected (<1)	10/14/2020	n/a
201002051-004	5	10/2/2020	HS 1st Fl South	Bottle Fill	Initial	Not Detected (<1)	10/14/2020	n/a
201002051-005	6	10/2/2020	HS 1st Fl West	Bottle Fill	Initial	Not Detected (<1)	10/14/2020	n/a
201002051-006	7	10/2/2020	HS Cafeteria	Drinking Water Sink (Left)	Initial	Not Detected (<1)	10/14/2020	n/a
201002051-007	8	10/2/2020	HS Cafeteria	Drinking Water Sink (Right)	Initial	1.8	10/14/2020	n/a
201002051-008	9	10/2/2020	HS Cafeteria	Prep Sink	Initial	10.1	10/14/2020	n/a
201002051-009	10	10/2/2020	HS Cafeteria	Steam Kettle	Initial	Not Detected (<1)	10/14/2020	n/a
201002051-010	11	10/2/2020	HS Cafeteria Sandwich bar	Sink	Initial	4.7	10/14/2020	n/a
201002051-011	12	10/2/2020	HS Front Entrance Faculty Room	Sink	Initial	Not Detected (<1)	10/14/2020	n/a
201002051-012	13	10/2/2020	HS Nurses Office	Sink	Initial	Not Detected (<1)	10/14/2020	n/a
201002051-013	14	10/2/2020	HS Gym Area	Bottle Fill	Initial	Not Detected (<1)	10/14/2020	n/a
201002051-014	15	10/2/2020	HS Gym	Ice Maker	Initial	Not Detected (<1)	10/14/2020	n/a