

LAKE GEORGE CENTRAL SCHOOL DISTRICT

381 CANADA STREET, LAKE GEORGE, NY 12845

TELEPHONE: 518-668-5456

FAX: 518-668-2285

-

January 10, 2017

Water Testing & Remediation Update

Beginning in late October we remediation was implemented for high-priority areas, including sinks in the ES Kitchen and HS Family & Consumer Science Room, and ES classroom sinks and fountains. A total of 8 locations were repaired, and 2nd round water testing occurred.

The results of the 2nd round testing were positive for all locations except the bubbler in the ES Intermediate II Cluster. The initial remediation was a replacement of the bubbler, we will now replace the pipe and fittings leading from the water supply to the bubbler. Remediation will also occur on priority 2,3 and 4 locations. These areas will be re-tested, and any location that does not meet limits.

Laboratory sinks that tested above limits will be permanently identified as non-potable water. District Policy and Procedures will include notification that eating and drinking in laboratory space is not permitted. These precautions will bring us into compliance for the 20 laboratory sinks that tested above NYS limits.

Test results from the 2nd round are included with this update. Highlighted locations are still under remediation. All other locations have been remediated, removed from service or designated non-potable laboratory sinks.

LAKE GEORGE CENTRAL SCHOOL DISTRICT

381 CANADA STREET, LAKE GEORGE, NY 12845

TELEPHONE: 518-668-5456

FAX: 518-668-2285

Lake George Elementary School		Lead (Pb)	Priority	Date	Remediation	Re-Test	Re-Test
Sample Location	Analytical Result			Remediate	Action	Date	Result
ES FOOD SERVICE #7	0.03	1		10/24	new sprayer	11/11/2016	0.0013
INT. II #1	0.015	#1 fountain		11/1/16	new fountain	11/11/2016	0.0701
INT. II #9	0.021	#2		11/1/16	aerator	11/11/2016	0.0023
INT. II #10	0.021	#2					
INT. II #18	0.016	#1 fountain		11/1	new fountain	11/11/2016	0.0062
PRIMARY #22	0.038	#2		11/1/2016	aerator	11/11/16	0.0027
MENS ATHLETIC OFFICE SINK	0.036	#4		11/1/16	aerator	11/11/2016	0.0026
FOREIGN LANGUAGE CLUB SINK	0.11	#3					
CORE ROOM SINK #1	0.056	#3					
OTPT SINK	0.031	#3					
ART ROOM SINK #3	0.02	#4					
Lake George Jr. Sr. High School		Lead (Pb)	Priority	Date		Re-Test	Re-Test
Sample Location	Analytical Result			Remediate		Date	Result
LGHS 024-SCIENCE RM.007(SINK)#2	0.016				new policy	N/A	
LGHS 028-SCIENCE RM. 005(SINK)#2	0.037				new policy	N/A	
LGHS 029-SCIENCE RM. 005(SINK)#3	0.025				new policy	N/A	
LGHS 030-SCIENCE RM. 005(SINK)#4	0.025				new policy	N/A	
LGHS 031-SCIENCE RM. 005(SINK)#5	0.019				new policy	N/A	
LGHS 037-SCIENCE RM. 009(SINK)#1	0.017				new policy	N/A	
LGHS 039-SICENCE RM. 009(SINK)#3	0.017				new policy	N/A	
LGHS 040-SCIENCE RM. 009(SINK)#4	0.015				new policy	N/A	
LGHS 043-SCIENCE RM. 009(SINK)#7	0.028				new policy	N/A	
LGHS 044-SCIENCE RM. 009(SINK)#8	0.024				new policy	N/A	
LGHS 046-SCIENCE RM. 009(SINK)#10	0.052				new policy	N/A	
LGHS 047-SCIENCE RM. 009(SINK)#11	0.03				new policy	N/A	
LGHS 051-SCIENCE RM. 010(SINK)#3	0.021				new policy	N/A	
LGHS 059-SCIENCE RM. 010(SINK)#11	0.29				new policy	N/A	
LGHS 066-BIOLOGY RM. 004(SINK)#1	0.077				new policy	N/A	
LGHS 067-BIOLOGY RM. 004(SINK)#2	0.075				new policy	N/A	
LGHS 069-BIOLOGY RM. 004(SINK)#4	0.021				new policy	N/A	
LGHS 071-BIOLOGY RM. 004(SINK)#6	0.025				new policy	N/A	
LGHS 075-SCIENCE RM. 003(SINK)#1	0.06				new policy	N/A	
LGHS 076-SCIENCE RM. 003"STORAGE"(SINK)	10.8				new policy	N/A	
LGHS 097-BOYS BATHRM. "ADJ. STAGE"(SINK)#3	0.016						
LGHS 099-GIRLS BATHRM. "ADJ. STAGE"(SINK)#2	0.022						
LGHS 100-GIRLS BATHRM. "ADJ. STAGE"(SINK)#3	0.015						
LGHS 103-RM. 115B(SINK)	0.47						
LGHS 105-HOME ED RM. 116(SINK)#1	0.095	1		10/18	new faucet	11/11/2016	0.0035
LGHS 106-HOME ED RM. 116(SINK)#2	0.39	1		10/18	new faucet	11/12/2016	0.003
LGHS 122-OFFICE RM. 124 "BATHRM."(SINK)	0.039						
LGHS 123-CSE OFFICE/SPECIAL BD(SINK)	1.7	Removal				N/A	